

**BIDS AND AWARDS COMMITTEE  
Supplemental Bid Bulletin No. 2  
September 13, 2017**

**Supply Delivery and Installation of Soundproofing of the  
DOF Building (3<sup>rd</sup> to 6<sup>th</sup> Floor) Project**

This Supplemental Bid Bulletin No. 2 is issued to defer the bid opening for the Supply, Delivery and Installation of Soundproofing of the DOF Building (3<sup>rd</sup> to 6<sup>th</sup> Floor) Project.

REFERENCE	AMENDMENT/CHANGES/CLARIFICATION												
Page 5 Invitation to Bid 6. The schedule of bidding activities shall be as follows: <table border="1" data-bbox="246 1024 761 1236"> <thead> <tr> <th align="center">Activities</th> <th align="center">Schedule</th> </tr> </thead> <tbody> <tr> <td>Deadline for Submission of Bids</td> <td>Sept 13, 2017 9:45 a.m.</td> </tr> <tr> <td>Opening Bids</td> <td>Sept. 13, 2017 10:00 a.m.</td> </tr> </tbody> </table>	Activities	Schedule	Deadline for Submission of Bids	Sept 13, 2017 9:45 a.m.	Opening Bids	Sept. 13, 2017 10:00 a.m.	Page 5 Invitation to Bid 6. The schedule of bidding activities shall be as follows: <table border="1" data-bbox="824 1024 1390 1236"> <thead> <tr> <th align="center">Activities</th> <th align="center">Schedule</th> </tr> </thead> <tbody> <tr> <td>Deadline for Submission of Bids</td> <td>Sept 20, 2017 9:45 a.m.</td> </tr> <tr> <td>Opening Bids</td> <td>Sept 20, 2017 10:00 a.m.</td> </tr> </tbody> </table>	Activities	Schedule	Deadline for Submission of Bids	Sept 20, 2017 9:45 a.m.	Opening Bids	Sept 20, 2017 10:00 a.m.
Activities	Schedule												
Deadline for Submission of Bids	Sept 13, 2017 9:45 a.m.												
Opening Bids	Sept. 13, 2017 10:00 a.m.												
Activities	Schedule												
Deadline for Submission of Bids	Sept 20, 2017 9:45 a.m.												
Opening Bids	Sept 20, 2017 10:00 a.m.												
Page 73 Technical Specifications Sound testing before and after the installation of the soundproofing panels	Page 73 Technical Specifications Sound testing before and after the installation of the soundproofing panels. The result should not exceed 40 dB in all areas.												

For guidance and information of all concerned.

**GIL S. BELTRAN**  
Undersecretary and  
BAC Chairman